



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RD022	5.6	Pendent	SR	5 mm	1/2	Brass, Chrome, Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: Rapidrop Global, Ltd., Rutland Business Park, Newark Road, Peterborough, PE1 5WA, United Kingdom

Manufacturing Location: Rapidrop Global, Ltd., Rutland Business Park, Newark Road, Peterborough, PE1 5WA, United Kingdom

FM Approvals Class: 2017

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3050664

Approval Granted: October 7, 2013

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'Richard B. Dunne', is written over a horizontal line.

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group